PROCENTEC





ProfiHub B5+R

User manual

Safety Guidelines

This manual contains notices which you should observe to ensure your own personal safety, as well as to protect the product and connected equipment. These notices are highlighted in the manual by a warning sign and are marked as follows according to the level of danger:



Draws your attention to important information on handling the product, a particular part of the documentation or the correct functioning of the product.

Warning

This device and its components may only be used for the applications described in this manual and only in connection with devices or components that comply with PROFIBUS and an RS 485 interface. This product can only function correctly and safely if it is transported, stored, set up, installed, operated and maintained as recommended.

Qualified Technicians

Only qualified technicians should be allowed to install and work with this equipment. Qualified technicians are defined as persons who are authorized to commission, to ground, to tag circuits and systems in accordance with established safety practices and standards. It is recommended that the technicians carry a Certified PROFIBUS Installer or Certified PROFIBUS Engineer certificate.

Disclaimer of Liability

We have checked the contents of this manual as much as possible. Since deviations cannot be precluded entirely, we cannot guarantee full agreement. However, the content in this manual is reviewed regularly and any necessary corrections included in subsequent editions. Suggestions for improvement are welcomed.

Copyright © 2019 PROCENTEC

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written permission of the publisher.

Important information

Purpose of the Manual

This manual explains how to put the ProfiHub B5+R / B5+RD into operation.

Recycling and Disposal

The parts of the ProfiHub can be recycled. For further information about environment-friendly recycling and the procedure for disposing your old equipment, please contact:

PROCENTEC Klopperman 16 2292 JD WATERINGEN The Netherlands

Tel.: +31-(0)174-671800 Fax: +31-(0)174-671801 Email: info@procentec.com

Document Updates

You can obtain constantly updated information on PROCENTEC products on the Internet at www.procentec.com

You can also contact PROCENTEC Customer Support:

- by phone at +31-(0)174-671800
- by fax at +31-(0)174-671801
- by email at support@procentec.com

Important notices

WARNING

When the product is in use at an ambient temperature of 63 degrees Celsius or 145 degrees Fahrenheit, the housing of the ProfiHub B5+ will be hot. **Do not touch the housing!**

At normal operating temperatures of 25 degrees Celsius, the temperature of the housing will not exceed 35 degrees Celsius.

WARNING

When the product is in use at an ambient temperature of 63 degrees Celsius or 145 degrees Fahrenheit, the housing of the ProfiHub B5+ will be hot. **Do not touch wires which are in contact with the housing!**

WARNING

When the product is in use at an ambient temperature of 63 degrees Celsius or 145 degrees Fahrenheit, the housing of the ProfiHub B5+ will be hot. Use wires suitable for these temperatures!

HOT HOUSING warning located on the side of the housing. Make sure this warning is visible after wall installation. UL certification demands the warning to be visible during operation.

To comply with UL certification regulations (UL60950-1) the power supply must be a Limited Power Source (LPS) or NEC Class 2 or CEC Class 2 that cannot exceed 100VA.

According to UL60950-1, if a copper PROFIBUS cable is used outside, it is required to install surge protection that is suitable for PROFIBUS.

To comply with UL certification regulations the ProfiHub B5+ is to be used on altitudes under 2000 m.

Contents

Important information	3
Important notices	4
Contents	5
1. Product Description	7
1.1 Product Features	8
1.2 Application areas	9
1.3 Additional Benefits	9
1.4 Channel Structure	10
1.5 Grounding System	11
1.6 Cable lengths for PROFIBUS DP	11
1.7 Cable types for PROFIBUS DP	12
1.8 Status LEDs	13
1.8.1 The red error LED	13
1.9 Comparison table	14
2 Installation Instructions ProfiHub B5+R	15
2.1 Location	15
2.2 Position	15
2.3 Mounting	15
2.4 Power Supply	16
2.5 Grounding of the power	17
2.6 Relay contact	
2.7 Backbone	18
2.8 Spur Segments	19
2.9 Termination	20
2.10 Baudrate switch	21
2.10.1 B5+ (all serial numbers starting with 18 or lower)	21
2.10.2 B5+R (All serial numbers starting with 19 or higher)	22
2.11 Robust Repeating Mode	22
2.11Channel Redundancy	22
3 Diagnostics Device	23
3.1 Setting up the Diagnostics Device	
3.1.1 Enabling the Diagnostics Device	
3.1.2 Changing the default PROFIBUS address	
3.1.3 GSD file	27
3.2 Configuring the Diagnostic Device	27
3.2.1 Info data (mandatory module)	27
3.2.2 Alarm Confirmation	27
3.2.3 Redundant Status	27
3.2.4 Baudrate Status	28

	3.2.5	Relay Status	28					
	3.2.6	Power Status	28					
	3.2.7	Termination Status	29					
	3.2.8	Channel Status	29					
	3.2.9	9 Livelist Status						
	3.2.10	Statistics (Short Format, Long Format)	30					
	3.3 Par	ameterizing the Diagnostic Device	32					
	3.3.1	Diagnostics	32					
	3.3.2	Statistics	33					
	3.3.3	Extended Diagnostics on Events change	33					
	3.3.4	Extended Diagnostics on Statistics change	34					
	3.3.5	Alarm Relay on Events change	35					
	3.3.6	Alarm relay on Statistics change	35					
	3.3.7	Changing the Diagnostics duration/timeout	36					
	3.3.8	Changing the Device Lost timeout	36					
	3.3.9	Changing the data format	37					
	3.4 Pro	fiTrace plugin for the Diagnostic Device	37					
	3.4.1	Installing the Plugin	37					
	3.4.2	Using the Plugin	39					
4	Tech	nical Data ProfiHub B5+R	40					
5	Orde	r codes	44					
6	Glossary							
8	Revision History							
9	Sales	offices and Distributors	49					
9	Certi	ficates	54					
9	Note	S	57					
Ab	out PRC	DCENTEC	59					

1. Product Description

ProfiHub B5+R is an advanced, flexible and robust network component for PROFIBUS DP installations, to create backbone structures and long multi-device star/tree segments.

PROFIBUS DP is a high speed communication bus that must comply with strict rules concerning spur lines, because of possible reflections that could lead to communication disturbances. If spur lines or star segments are required, costly investments in repeaters have to be done.

The innovative ProfiHub B5+R is the perfect component for such applications. It is an economic solution to realise reliable spur lines in high speed DP networks. They have the functionality of 5 galvanic isolated transparent repeaters. This allows network structures with extended spur lines that individually can handle a maximum of 31 devices and a length equal to the main bus. The ProfiHub B5+R refreshes a received message on one Channel and transfers it to all the other Channels (chicken foot topology).

Because the ProfiHub B5+R creates isolated segments, the devices can now be removed and added during operation. Also most electrical bus problems and EMC disturbances in a spur do not spread to the other segments. The intelligent logic and isolation circuits of the ProfiHubs do not change the bit width. This means the ProfiHubs do not have limitations in serial placement. The logic also detects the transmission speed automatically.

To assist the installation work, termination is integrated and can be switched on/off. The grounding concept is also selectable: direct or capacitive grounding. The ProfiHubs are powered by a 10 to 24 DC Voltage. For troubleshooting, maintenance and commissioning the ProfiHubs are equipped with LEDs on the outside, which indicate the status of each Channel (Data and Error).

If bus redundancy is enabled, 2 segments will form a redundant pair which is completely compatible with the ABB RLM01. An alarm contact is linked to events based on the status of the power supply and the bus redundancy status.



Fig. 1 - ProfiHub B5+R

1.1 Product Features

- 5 Galvanic isolated outgoing channels (repeater segments)
- Advanced Diagnostic capabilities
- Transparent for all PROFIBUS DP protocols
- DP RS 485 specifications for each channel
- Cable redundancy for channel 4+5
- 9.6 Kbps to 12 Mbps.
- 31 devices per channel
- 1200 m spur line length (depending on transmission speed)
- Redundant power supply
- No limit in serial placement or cascading of ProfiHubs (only limited by busparameters)
- Alarm contact, with manual reset button
- No address required (except for the B5+R Diagnostics option)
- Integrated termination facilities (switches)
- Configurable grounding system (direct or capacitive)
- IP 20 classification
- Increased temperature range
- DNV / offshore Certification
- UL approvals




Fig. 2 - ProfiHub connections




Fig. 3 - Long spur lines to instruments and the possibility to remove/insert them during operation. Short circuit protection on each spur line is automatically provided.

1.2 Application areas

- Dynamic spur lines to actuators, flow meters and pH analyzers
- Removable drives and motors
- Pull/Plug motor control centers (drawers)
- Roof mounted devices in tank farms
- Barrier for non galvanic isolated equipment
- Networks with requirement for High Availability/uptime
- Large star/tree structured networks

1.3 Additional Benefits

- Hot slave insertion and removal during operation
- Short circuit protection on each Channel
- Option to create a redundant path to other Hubs or ComBricks
- Compact and robust construction
- Status and error display (per Channel)
- Suitable for all DP cables
- Conveniently arranged networks
- Easy extendable installations
- On-board DB9 female connector on each channel for maintenance activities
- Cost Savings




Fig. 4 - Because of the isolation and intelligence the ProfiHub provides, it can be used as a barrier for electrically sensitive segments. This keeps the backbone and other Channels clean.

1.4 Channel Structure

Each Channel is electrically isolated and internally connected to the transparent intelligent backbone. The termination is switchable and powered by the ProfiHub. The shielding of the PROFIBUS cable can be directly grounded or indirectly grounded (see the next paragraph).




Fig. 5 - Channel structure

1.5 Grounding System

The ProfiHub B5+R can be grounded by 3 methods:

- 1. Direct grounding on the Ground Rail
- 2. Indirect grounding (through a capacitor)
- 3. Combination of direct and indirect.

The power supply must be grounded directly on the Ground Rail. The shielding of the PROFIBUS cables can be directly or indirectly grounded. If you do not want to ground all or some cables to the common ground, i.e. compensating current, the cable shielding must be connected to pin 'l' which stands for Indirect grounding. A capacitor with a parallel high value resistor will separate the 2 potentials (Fig. 5), ensuring protection of the signal against non-DC disturbances.

If by accident on 1 channel the Direct Grounding is connected with the Indirect Grounding, the connection to the Direct Grounding bypasses the capacitor in the Indirect Ground connection. The current on the shield will flow to Direct Ground.

1.6 Cable lengths for PROFIBUS DP

The cables on the Channels and the Main-Channel must comply with the PROFIBUS DP cable specifications for RS 485 (Fig. 6).

Baudrate (kbit/s)	9.6	19.2	45.45	93.75	187.5	500	1500	3000	6000	12000
Segment length (m)	1200	1200	1200	1200	1000	400	200	100	100	100
Segment length (feet)	3940	3940	3940	3940	3280	1310	656	328	328	328




Fig. 6 - Cable lengths for PROFIBUS DP

1.7 Cable types for PROFIBUS DP

The cable type must comply with the PROFIBUS DP cable specifications for RS 485 (Fig. 7).

Parameter	Value
Wires	2 (twisted)
Impedance	135 165 Ohm at 3 to 20 MHz
Capacity	< 30 pF/m
Loop resistance	< 110 Ohm/km
Wire diameter	> 0.64 mm
Wire area	> 0.32 mm ²

Fig. 7 - PROFIBUS DP cable specifications

The ProfiHub B5+R can handle cables based on multiple protection sheaths with an overall cable diameter between 6 to 12 mm (Fig. 8).




Fig. 8 - Cables with different protection sheaths.

1.8 Status LEDs

The Status LEDs on the ProfiHub are very useful for diagnostics.

	OFF	Blinking	ON
POWER 1 / 2	Power is not switched on or an internal failure	Ower supply not stable, redundant power supply interrupted or an internal failure	Power supply OK.
READY	Power is not switched on or an internal failure	Orrying to detect the transmission speed, but has not locked it yet	The transmission speed has been detected.
Main RX-OK	No communication detected on the Main-Channel	1 or more devices communicating on the Main-Channel	1 or more devices communicating on the Main-Channel
Main ERROR	No problem has been detected	Problem in the cabling has been detected (Main Channel)	Problem in the cabling has been detected (Main Channel)
Channel RX-OK	There is no communication detected (on this Channel)	1 or more devices communicating (on this Channel)	1 or more devices communicating (on this Channel)
Channel ERROR	No problem has been detected	Problem in the cabling has been detected (on this Channel)	Problem in the cabling has been detected (on this Channel)
INT. TERM	Termination for this channel is OFF	Internal failure	Termination for this channel is ON

1.8.1 The red error LED

The red error LEDs will blink shortly if a corrupt message enters the ProfiHub. More specifically, this can be a Parity error (the parity checksum of the byte is incorrect) or a Framing error (the FCS byte is different than the real message). It is necessary to investigate further with an oscilloscope to find out what the problem is. This can easily be done with ProfiTrace.

Another reason for the red error LED for channel 4 or 5 is a problem in the redundant cabling (if the ProfiHub is set to redundant). If the redundant line is fixed, press the 'Alarm Reset' button.

It can also be that the baudrate is not locked (no PROFIBUS master on the bus).

1.9 Comparison table

	ProfiHub A5	ProfiHub B5	ProfiHub B5+R
Area	IP 65	IP 20	IP 20
Redundant power supply No		No	Yes
Temperature range	-20 to +60° Celcius	-20 to +60° Celcius	-25 to +70° Celcius
Housing	Plastic	Metal	Metal
Mounting	Corner screws	DIN-rail	DIN-rail
Weight	800 g	650 g	650 g
Dimensions	213 x 210 x 95 mm	167 x 113 x 35 mm	167 x 113 x 35 mm
PROFIBUS connectors	Screw terminals (inside) Glands (outside)	Screw terminals and DB9 connectors	Screw terminals and DB9 connectors
Alternative connectors	Glands can be replaced by M12 connectors	No	No
Termination LEDs	No	Yes	Yes
Ground rail	Optional	Yes	Yes
Redundant channel	No	No	Yes
Diagnostics Device	None	None	Yes
Offshore approvals	None	None	Yes
UL approvals	None	None	Yes

2 Installation Instructions ProfiHub B5+R

2.1 Location

The ProfiHub B5+R can be installed everywhere in a non-hazardous area that complies with IP 20 (DIN 40 050) and the specified temperature range of -25 to $+70^{\circ}$ Celsius.

2.2 Position

The ProfiHub B5+R can be installed in every position, but it is recommended to install it with the cables pointing down. In this position it is also easier to read the status LEDs.

2.3 Mounting

The ProfiHub B5+R can be mounted on 35 mm DIN-rail with a minimum width of 167 mm. Mounting brackets are available for mounting the B5+R directly on a wall. The ProfiHub B5+R has only been UL and DNV approved with 35 mm DIN-rail mounting!

The supplied rubber studs need to be placed on the back of the housing of the ProfiHub B5+R for extra fixation. This is to prevent the product to potentially slide off the DIN-rail. See Fig. 9 for an example. When used in DNV environments these rubber studs need to be installed!



Fig. 9 – Rubber studs on backside of housing

2.4 Power Supply

To comply with UL certification regulations the power supply must be a Limited Power Source (LPS) or NEC Class 2 or CEC Class 2 that cannot exceed 100VA.

The two 2-pin screw type power connectors are located on the left of the ProfiHub B5+R (Fig. 10). 1 = + (left)

2 = - (right)




Fig. 10 - Power connectors and LEDs

Both power connectors are linked 1-on-1 to the internal power supply of the B5+R. If one power supply fails, the other takes over without delay time. When redundancy is not required, it is sufficient to use one power connector. Please note that when using only one power supply, a voltage of max. 0.25 V will exist on the other unconnected power connector, as shown in Fig. 11.

If only one power supply is used, the alarm contact is closed. If two power sources are connected, the contact is open. As soon as one of the power supplies fails, the contact will close and the Power Indicator LED will blink.




Fig. 11 - Maximum voltage on unconnected Power Connector

For UL certified installations the power supply must comply with the following specifications:

- Limited Power Source (LPS) or NEC Class 2 or CEC Class 2
- Voltage: 12 24 VDC
- Current: min 130 mA
- Wire diameter: < 2.5 mm²

Procedure

To connect the 24V supply to the 2-pin screw-type terminal, proceed as follows:

- Strip the insulation from the cable or the conductors for the 24V power supply.
- Add cable crimp terminals/wire ferrules to the conductors.
- Secure the crimp terminals in the screw-type terminal.

To connect the power supply, you need a 3 mm screwdriver.

Testing

 (\mathbf{i})

If the power is switched on it can be diagnosed by the following indicators:

- LEDs should be blinking in a circular animation for a short time.
- The POWER LED of the respective power connector (1, 2 or both) is ON.
- The READY LED is ON or Blinking, depending on baud rate lock.

2.5 Grounding of the power

It is recommended to use a power supply with a ground lead (3-wire). Connect the ground lead of the power lead to the Ground Rail of the ProfiHub B5+R. Connect the Ground Rail to the common ground with a separate ground lead. See Fig. 12 for an example.



Fig. 12 - Connection to Ground Rail

2.6 Relay contact

The ProfiHub B5+R features a potential-free relay contact. This alarm contact can be used to monitor the power supplies. Example applications are: Connect a LED tower, alarm buzzer, SMS server or use it as a digital signal for the PLC. The relay can also be used for alarming in case of retires, illegals, or other events. For more information refer to Chapter 3.

If only one power supply is used, the alarm contact is closed after 60 seconds after start-up. If two power sources are connected, the contact is open. When one of the power supplies fails for 3 seconds or more, the contact will close and the Power Indicator LED will blink. If you are using only one power source and wish to use the Relay contact, simply connect Power 1 to Power 2.

In the case of an interrupted power supply you can reset the contact by pressing the 'Reset' button. The contact will open and the LEDs will stop blinking.

The Alarm contact is also switched when the ProfiHub is in Redundant mode and one of the redundant paths fails.

The maximum power to be connected to the alarm contact is 24 VDC. The maximum current consumption is 500 mA.

It is advised to use a Limited Power Source (LPS) of NEC Class 2 or CEC Class 2 for powering the alarm contact.

2.7 Backbone

Connect the DP backbone cable to the bottom-left connector of the Main-Channel (Fig. 13). If the ProfiHub is not the last device on the bus segment, connect the Bus-Out cable to the right connector of the Main-Channel (Fig. 13). The second method is to place a PROFIBUS standardized plug with an in/out cable on the DB9 connector.




Fig. 13 - PROFIBUS DP backbone connection

Pin layout of the screw terminals Pin "A": Green wire

Pin "B": Red wire Pin "I": Indirect cable shielding Note: Connecting the Indirect cable shielding is not required when the ground clips are used.

Testing

• If the Main-Channel recognizes valid PROFIBUS messages from one or more connected devices, the RX-OK LED of the Main Channel should be blinking.

2.8 Spur Segments

Connect the spur segments to the connectors of Channel 1 to 5 (Fig. 14). The second method is to place a PROFIBUS standardized plug on the DB9 connector of the specific Channel.




Fig. 14 - PROFIBUS DP spur connectors

Pin layout of the screw terminals:

Pin "A": Green wirePin "B": Red wirePin "I": Indirect cable shieldingNote: Connecting the Indirect cable shielding is not required when the ground clips are used.

Testing

• If a Channel recognizes valid PROFIBUS messages from one or more connected devices, the RX-OK LED of the Channel should be blinking.

According to UL60950-1, if a copper PROFIBUS cable is used outside, it is required to install surge protection that is suitable for PROFIBUS.

2.9 Termination

The termination of the Main-Channel has been set to OFF by default. If the ProfiHub is the last device on the segment, the termination must be set to ON (Fig. 15).

The terminations of the Channels have been set to ON by default, because it is assumed that the new segment is started at the ProfiHub (Fig. 15).




Fig. 15 - Termination Switches

The termination LED of the corresponding Channel is activated when the termination switch is set to ON.



When the DB9 connector is used and the cable starts at the ProfiHub, it is recommended to use the termination on the DB9 plug and NOT the ProfiHub. This way, the connector can be removed while maintaining termination on the bus.

2.10 Baudrate switch

2.10.1 B5+ (all serial numbers starting with 18 or lower)

If the serial number of your ProfiHub starts with <u>18 or lower</u>, follow this paragraph for the dipswitch settings.

The ProfiHub B5+R recognizes the transmission speed by default. If it is required that the ProfiHub B5+R is locked to a certain transmission speed, the baudrate switch should be set to the required value (Fig. 16).




Fig. 16 - Baudrate speed switch

To set the rotary switch, use a 3 mm screwdriver.

Switch values:

- 0 = Normal repeating, Auto baudrate detect (default)
- 1 = fixed 9.6 kbps, diagnostics device ON (B5+RD only)
- 2 = fixed 19.2 kbps, diagnostics device ON (B5+RD only)
- 3 = fixed 45.45 kbps, diagnostics device ON (B5+RD only)
- 4 = fixed 93.75 kbps, diagnostics device ON (B5+RD only)
- 5 = fixed 187.5 kbps, diagnostics device ON (B5+RD only)
- 6 = fixed 500 kbps, diagnostics device ON (B5+RD only)
- 7 = fixed 1500 kbps, diagnostics device ON (B5+RD only)
- 8 = fixed 3000 kbps, diagnostics device ON (B5+RD only)
- 9 = fixed 6000 kbps, diagnostics device ON (B5+RD only)
- A = fixed 12000 kbps, diagnostics device ON (B5+RD only)
- B = Robust repeating, Auto baudrate detect, diagnostics device ON (B5+RD only)

C = Robust repeating, Auto baudrate detect, redundancy on channel 4 and 5, diagnostics device ON (B5+RD only)

- D = Normal repeating, Auto baudrate detect, diagnostics device ON (B5+RD only)
- E .. F = Reserved for future use

Please note that the position of the rotary switch is only sampled during start-up. Changing the position of the switch will not have effect during operation.

The auto baudrate detect feature will search for the correct baud rate within 10 seconds of receiving the first telegram. This baud rate lock will be lost after 50 seconds of incorrect or no message reception.

2.10.2 B5+R (All serial numbers starting with 19 or higher)

If the serial number of your ProfiHub starts with <u>19 or higher</u>, follow this paragraph for the dipswitch settings.

To set the rotary switch, use a 3 mm screwdriver.

The rotary switch for the B5+R has the following options: Switch values:

Rotary switch	Auto detect	Robust repeating	Redundancy	Diagnostic slave
0	•			
1	٠	•		
2	•	•	•	
3	٠			•
4	•	•		•
5	•	•	•	•
6-F	•			

A change of the rotary switch setting is immediately active without restarting the device.

The auto baudrate detect feature will search for the correct baud rate within 10 seconds of receiving the first telegram. This baud rate lock will be lost after 50 seconds of incorrect or no message reception.

In robust repeating mode, only messages starting with a valid PROFIBUS start delimiter are repeated (SD1, SD2, SD3, SD4 and Short Acknowledge). In Normal mode, every bit is transferred immediately onto the other channels.

2.11 Robust Repeating Mode

The B5+R has two repeating modes: normal (rotary switch setting 0 and 3) and Robust Repeating (rotary switch setting 1, 2, 4 or 5). In normal mode the bits are transferred directly on the other channel with a minimal delay (see delay times in the Technical Data chapter). In Robust mode, the first byte is checked to verify if the following bits are a real PROFIBUS message. If the byte is corrupt, the message will not be transferred to the other channel. This helps network stability in EMC sensitive environments.

ATTENTION:

Using the ProfiHub B5+R in Robust Repeating mode causes a delay in processing the telegrams. It is required to increase the default MinTSDR in the PLC busparameters slightly. Recommended is to increase the MinTSDR with a value according to the Delay Time table, column 'Robust Mode', described in the Technical Data chapter. Generally a MinTSDR of 25 is sufficient.

2.11 Channel Redundancy

To use the Redundancy option of the B5+R, set the rotary switch to 2 or 5. This enables the last two channels (4 and 5) to be one redundant path to any other ProfiHub, to a redundant ComBricks, or to any other supporting product. See Fig. 17 for an example.




Fig. 17 - Redundant path between two ProfiHubs

The telegrams are transferred onto both redundant channels. The logic inside the ProfiHub determines which telegram is used to be transferred onto the other channels. A message received by a redundant channel is repeated on all other channels, except the other redundant channel. A message received by a normal channel is repeated on all other channels.

When one redundant cable breaks, the other cable ensures safe delivery of the telegram. In this event the built-in alarm contact will close. The red 'ERROR' LED will blink with an interval of 100ms. When the redundant path is fixed, press the 'ALARM RESET' pushbutton to reset the alarm.

ATTENTION:

Using the ProfiHub B5+R in Redundancy mode causes a delay in processing the telegrams. It is required to increase the default MinTSDR in the PLC busparameters slightly. Recommended is to increase the MinTSDR with a value according to the Delay Time table, column 'Robust Mode', described in the Technical Data chapter. Generally a MinTSDR of 25 is sufficient.

3 Diagnostics Device

The B5+R comes with a built-in Diagnostics Device. The Diagnostics Device is a very versatile statistics/diagnostics logger. It can be used to keep track of the overall PROFIBUS network health and inform the PLC or DCS of any network failure such as repeats or illegals, missing ProfiHub termination, live list changes, or power supply problems. Audible or visible feedback is also possible by automatically switching the integrated alarm relay.

You can use a ComBricks to display the most important diagnostics of every channel. The information of this ProfiHub Diagnostics slave is displayed as follows:

PROCENTEC									
ComBricks	IP address: 192.168.	13.237	MAC add		06:00:1C:04		· · · · ·	0 days, 19:37	
COMBRICKS	Site:				Temperature: 41°C System time: 4-Jan-2019 9:50:51			:51	
• <u>Status</u>	Company:				Co	ountry:			
• <u>System log</u>	ProfiHub d	iagnos	stic sla	ave inf	o				
• <u>Channel list</u>									
• <u>Diagnostic slave info</u>	ProfiHub B5+RD (Ad	dress: 20 (Up	oper-Left), Se	erial#: 13207) 🔻	Clear sel	ected device	ĺ	Show overview
ProfiTrace OE:	Diagnostic slave info	,							
• <u>Live list</u>	Last update:					4-	Jan-2019 9:50	:44	
<u>Statistics</u>	Profihub type and seria	loumberi					B5+RD (Serial		
• <u>Message recording</u>	Profihub firmware vers					FIOIIIIdo	V2.0	#, 13207)	
• <u>Network event log</u>								`	
• E-mail & Log event config	Profihub diagnostic sla						20 (Upper-Left		
<u>Output event config</u>		Bricks:				Network	1 (Module 1, C		
SNMP event config	Redundancy status:						Redundancy O	K	
• <u>Tag-name config</u>	Power 1 connected:						Yes		
Special modules:	Power 2 connected:						Yes		
•	Alarm status:					Inacti	ive		Reset alarm
• <u>Oscilloscope images</u>									
• <u>Osci</u> <u>scope errors</u>									
• <u>Bargraph images</u>									
• <u>Oscilloscope config</u>	SETTINGS O POWER 1	O RKOK	O RKOK	O RECK	O RKOK	0 RKOK 0 59609	0 RKCK 0 STROB		
Configuration:	O READY	O INT.TERM	O INT.TERM	O INT.TURM	O INT.TIRM	O INT.TIR	M Ø INT.TERM		
<u>General config</u>		-	-	-	-	-	•		
• <u>Network config</u>	ProfiHub								
• <u>IP config</u>									
• Password & user config	ALAFM DIAGNOSTICS	TERM.	TERM.	TERM.	TERM.	TERM.	TERM.		
• E-mail account config	12-24VDC	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF		
• Device management	POW,1 POW,2	ABI	ABI	ABI	ABI	ABI	A B I		
• <u>User message</u>						Den La Car			
• Diagnostic slave config	88	88	88	8 6	88	86	88		
• <u>Update license</u>	Termination:	On	On	On	On	On	On		
Not logged in.	Illegals:	0	0	0	0	0	0	Reset illegals	
Login	Internal Diag slave	Main	Ch 1	Ch 2	Ch 3	RED Ch 4	RED Ch 5		
	20	1	50	70	21	22	The second se		
		2		71	40	<u>23</u>			
				72	41	24			
				73	42	60			
						61			

Fig. 18 - Information window of the Diagnostic slave

It displays the following information:

- Address and Tag-name of the Diagnostic slave
- Type and serial number of the Diagnostic slave
- Firmware version of the Diagnostic slave
- Connection to the Network, Module and Channel number of the ComBricks
- Redundancy status of the ProfiHub
- Power status of the ProfiHub
- Alarm status (of the relay)
- Termination status of all channels
- Illegal count for all channels
- A live list of all channels

For more information see the ComBricks manual, paragraph 'Diagnostic Slave info'.

The diagnostic information can also be read easily with ProfiTrace because the Diagnostic Device sends this data over PROFIBUS. This enables maintenance engineers to immediately identify the affected segment in case of cable problems or instrument failure. Having a Diagnostics Device in your network dramatically decreases downtime because problems can be solved much quicker; it tells you where to look. SCADA applications can make this even easier.





Fig. 19 – Cable problems or node loss can be identified by the ProfiHub channel, and send this information over PROFIBUS to the PLC. ProfiTrace can also read this.

The following statistics and events are continuously monitored:

Events:	Statistics:
Alarm Relay opened/closed	Losts
Cable Redundancy change	Syncs
Baudrate change	Repeats (total)
Power input changed	Repeats (max. changed in 1 cycle)
Termination of Channel changed	Illegals
Communication on Channel stopped/started	Internal Diagnostics
Livelist changed (station removed or added)	External Diagnostics
	Diagnostics while in Data Exchange

All of these events and statistics can be transferred in four different ways, so that the PLC/DCS or user can be warned that something is happening in the PROFIBUS network: a PROFIBUS input message, a diagnostic message, an external diagnostics message, or it can trigger the built-in alarm relay.



3.1 Setting up the Diagnostics Device

3.1.1 Enabling the Diagnostics Device

To enable the Diagnostics Device in the ProfiHub, set the rotary switch on the top left side to position 3, 4 or 5 (for a complete list of rotary switch settings, refer to the Technical Data chapter).

3.1.2 Changing the default PROFIBUS address

By default the address of the Diagnostic Device is set to 126. To change the address, use a configuration tool which supports the 'Set Slave Address' command. Most configuration tools support this feature.

Class 2 commands dialog	
Set/Change Slave Address Diagnostics In	outs & Outputs Get Configuration Network scan
Set Slave Address	
Det Diave Address	Station address change successful
Current Address 126	
New Address 20	
Lock Address	
Change Address	

Fig. 21 - ProfiCaptain changes the address from 126 to 20

3.1.3 GSD file

Locate and download the appropriate GSD file for the Diagnostics Device on www.procentec.com/downloads . The correct GSD file for the ProfiHub B5+RD is: **PROC6970.gsd**. The zip file also contains the corresponding .bmp (Bitmap) files. Import the GSD file into your configuration tool and insert the device in the PLC hardware configuration.

3.2 Configuring the Diagnostic Device

The Diagnostic Device has many configuration options. It can be configured modularly. This paragraph describes all the available options per module in list order.

3.2.1 Info data (mandatory module)

There is only one mandatory module, which is the first module in the list ("INFO DATA MANDATORY ON 1st SLOT"). It has 4 input bytes with the following meaning:

Byte 1: Input Identifier byte (always 0xDE) Byte 2: Device type byte (0xB5 is ProfiHub B5+R) Byte 3: Version byte: 0x01 Byte 4: Data format byte (0x00 is Little Endian, 0x01 is Big Endian)

3.2.2 Alarm Confirmation

Input Identifier byte: 0x01

The Alarm Confirmation module has one Output, which can be used to reset the alarm. If the Alarm Relay has been triggered by any event (see paragraph 3.3.1), it can be reset by the PLC by sending 0x01 or higher to the output of this module.

3.2.3 Redundant Status

Input Identifier byte: 0x10

The next input byte is to indicate the status of the redundant path. It is divided in nibble 0..3 and 4..7.

Nibble 1 (03)	Meaning
1 dec	Redundancy not used
2 dec	Redundancy error left channel
3 dec	Redundancy error right channel
4 dec	Redundancy error both channels
5 dec	Redundancy OK
Nibble 2 (47)	
1 dec	Pending Alarm: Redundancy error left channel
2 dec	Pending Alarm: Redundancy error right channel
3 dec	Pending Alarm: Redundancy error both channels

Examples: 0x12 means Redundancy error on Left Channel, Pending alarm on Left Channel 0x05 means Redundancy OK

3.2.4 Baudrate Status

Input Identifier byte: 0x11

The next input byte is to indicate the baudrate lock status.

Dec	Meaning
1	No baudrate detected
2	9.6 Kbit
3	19.2 Kbit
4	45.45 Kbit
5	93.75 Kbit
6	187.5 Kbit
7	500 Kbit
8	1.5 Mbit
9	3 Mbit
10	6 Mbit
11	12 Mbit

3.2.5 Relay Status

Input Identifier byte: 0x12

The next input byte is to indicate the alarm relay status.

Hex	Meaning
00	Relay is off
01	Relay is on

3.2.6 Power Status

Input Identifier byte: 0x13

The next input byte is to indicate the status of the power inputs.

Nibble 1 (bit 03)	Meaning		
0	Power 1 is active		
1 Power 2 is active			
Nibble 2 (bit 47)			
4	Pending Alarm: Power 1 not active		
5	Pending Alarm: Power 2 not active		

Examples: 0x03: Power 1 and 2 are active 0x21: Power 1 is active, pending alarm: Power 2 not active 0x32: Power 2 is active, pending alarm: Power 1 and 2 not active (Relay should be reset in this case)

3.2.7 Termination Status

Input Identifier byte: 0x14

The next input byte is to indicate the status of the termination switches on the ProfiHub channels.

Bit	Meaning					
0	Main Channel termination ON					
1	Channel 1 termination ON					
2	Channel 2 termination ON					
3	Channel 3 termination ON					
4	Channel 4 termination ON					
5	Channel 5 termination ON					

Examples: 0x3F = All terminations are ON 0x01 = Only Main Channel termination is ON 0x10 = Only Channel 4 termination is ON

3.2.8 Channel Status

Input Identifier byte: 0x15

The next input byte is to indicate the communication status of the individual channels.

Bit	Meaning
0	Communication on Main Channel
1	Communication on Channel 1
2	Communication on Channel 2
3	Communication on Channel 3
4	Communication on Channel 4
5	Communication on Channel 5

Examples: 0x08 = Communication on Channel 3 0x0A = Communication on Channels 1 and 3 0x2C = Communication on Channels 2, 3 and 5

3.2.9 Livelist Status

Input Identifier byte: 0x20

The next input byte is to indicate which Channel is selected to display the Livelist status.

Hex	Meaning					
80	Livelist of Main Channel					
81	Livelist of Channel 1					
82	Livelist of Channel 2					
83	Livelist of Channel 3					
84	Livelist of Channel 4					
85	Livelist of Channel 5					
86	Livelist of this ProfiHub					
FF	Livelist of all channels (entire network)					

The next 32 input bytes are used for the actual Livelist data. Each address uses two bits. So the first two bits of the first byte are for address 0, the next two bits of the first byte are for address 1 and so on. The bits are used to indicate if the station is a slave device, master device or both.

Device:	Bit 1:	Bit 0:		
None	0	0		
Slave Device	0	1		
Controller	1	0		
Both	1	1		

Example: If there is a master device on address 2, and a slave device on address 3, then the first byte will be 0x60, because it will look like this:

Bit	7	6	5	4		3	2	1	0	
Value	0	1	1	0		0	0	0	0	
	Addres	is 3	Add	Address 2		Addres	s 1	Address	0	

This module also has 2 Output bytes. The first Output byte is used to select the Livelist of a specific Channel. This selection can be read-back in the Input byte described above.

Hex	Meaning					
80	Livelist of Main Channel					
81	Livelist of Channel 1 Livelist of Channel 2					
82						
83	Livelist of Channel 3					
84	Livelist of Channel 4					
85	Livelist of Channel 5					
86	Livelist of this ProfiHub					
FF	Livelist of all channels (entire network)					

The next Output byte can be used to reset the Livelist. Write 0x01 to this Output byte to reset the Livelist.

3.2.10 Statistics (Short Format, Long Format)

Input Identifier byte: 0x30 (short format) or 0x31 (Long Format)

The next byte is used to display the current selection of statistics that it sends.

Hex	Meaning
007E	Statistics for device 0126
7F	Statistics for undefined devices
80	Statistics of Main Channel
81	Statistics of Channel 1
82	Statistics of Channel 2
83	Statistics of Channel 3
84	Statistics of Channel 4
85	Statistics of Channel 5
86	Statistics of this ProfiHub
FF	Statistics of all channels (entire network)

The next 16 bytes (Short Format) or 32 bytes (Long Format) are used to transfer the statistics of the selected address, selected Channel or all Channels of the ProfiHub. Each statistic uses 2 bytes (Short Format, so a maximum of 65535 decimal per statistic) or 4 bytes (Long Format) and is sent in the following order:

- 1. Lost count
- 2. Sync count
- 3. Repeats total count
- 4. Repeats max per cycle count
- 5. Illegals count
- 6. Int. diagnostics count
- 7. Ext. diagnostics count
- 8. Diagnostics while in Data Exchange count

This module also has 2 output bytes. The first byte is used to configure the ProfiHub Statistics; you can choose which stations or Channels will display statistics. Configure it by sending the following output value:

Hex	Meaning		
007E	Statistics for device 0126		
7F	Statistics for undefined devices		
80	Statistics of Main Channel		
81	Statistics of Channel 1		
82	Statistics of Channel 2		
83	Statistics of Channel 3		
84	Statistics of Channel 4		
85	Statistics of Channel 5		
86 Statistics of this ProfiHub			
FF	Statistics of all channels (entire network)		

The next output byte can be used for clearing the statistics. Please note that the selected statistics of ALL node addresses and/or ProfiHub channels are cleared, not only for the displayed address or channel.

Bit	Meaning				
0	Clear LOST statistics				
1	Clear SYNC statistics				
2	Clear REPEATS TOTAL statistics				
3	Clear REPEATS MAX statistics				
4	Clear ILLEGALS statistics				
5	Clear INT. DIAG statistics				
6	Clear EXT. DIAG statistics				
7	Clear DIAG WHILE IN DX statistics				

Example: To clear all LOST and ILLEGALS statistics, send 0x11 To clear all statistics, send 0xFF

3.3 Parameterizing the Diagnostic Device

The Diagnostic Device has many user-definable parameters that can be changed, to alter the behaviour and options of the ProfiHub Diagnostics Device.

3.3.1 Diagnostics

The Diagnostics Device sends a diagnostic message on PROFIBUS whenever certain conditions are changed. These changes can be any of the following:

- Livelist change (a station added or removed)
- Bitrate error
- Alarm relay active
- Power status changed (one of the two power sources added or removed)
- Redundancy status change (one of the redundant cables added or removed)
- Termination status change (a termination switch on the ProfiHub has been changed)
- Channel status change (communication stopped or started on a channel)
- Statistics change (any statistic has changed)

In your configuration tool you can toggle the diagnostics for each item.

8		-	on dialog (c) 2003-2012 PROCENTE		1					
	Module Selection User Parameters Module Parameters Standard keywords User Definable Parameters									
	Offset			Value	Meaning	<u>^</u>	Min. Value	. 0		
1	3	BitO	Diag. on LiveList change	1	Enabled		Max. Valu	e 1		
	3	Bit1	Diag. on Baudrate status	1	Enabled		Default Va	alue: 1		
	3	Bit2	Diag. on Relay status	1	Enabled		New Valu	e [,] 1		
	3	Bit3	Diag. on Power status	1	Enabled		1101111010	. <u>j</u>		
	3	Bit4	Diag. on Redundancy status	1	Enabled			Apply value		
	3	Bit5	Diag. on Termination status	1	Enabled					
L	3	Bit6	Diag. on Channel status	1	Enabled	_		Reset To Default		
	4	Bill	STATISTIC. LOST CHANGED	1	Enabled		Allowed V	alues		
	4	Bit1	STATISTIC: SYNC CHANGED	0	Disabled	_				
	4	Bit2	STATISTIC: REPEATS TOTAL CHAN					Meaning		
	4	Bit3	STATISTIC: REPEATS MAX. CHANG	E 1	Enabled	_	0	Disabled Enabled		
	4	Bit4	STATISTIC: ILLEGALS CHANGED	1	Enabled			chabled		
	4	Bit5	Statistic: Int. Diag changed	0	Disabled					
	4	Bit6	Statistic: Ext. Diag changed	0	Disabled					
	4	Bit7	Statistic: Diag in DX changed	0	Disabled					
	<					P.				
	Raw para	ameter info i	in Hex							
	00 01 02 03 04 05 06 07 08 09 0A 0B 0C 0D 0E 0F 00 00 00 07 F 1D 00 00 03 26 01 00									
	Ok Cancel									

Fig. 22 - Screenshot of ProfiCaptain - User Parameter window

The 8th byte of a diagnostic message from the Diagnostic Device indicates which options have been enabled or disabled.

3.3.2 Statistics

You can choose which Statistics can trigger a diagnostic message, because not all statistics are interesting in all networks. For example, Syncs have been disabled by default because this is not a statistic that is suitable for PROFIBUS health monitoring.

ſ	GSD C	onfiguratio	on dialog (c) 2003-2012 PROCENTEC	C V1.3.6					
	Module S	election U	ser Parameters Module Parameters !	Standard	keywords				
	User Def	inable Para	meters						
	Offset	Datatype	Reference Name	Value	Meaning		Min. Value	0	
	3	Bit4	Diag. on Redundancy status	1	Enabled		Max. Value	1	
	3	Bit5	Diag. on Termination status	1	Enabled		Default Value:	1	
	3	Bit6	Diag. on Channel status	1	Enabled			1	-
1	4	Bit0	STATISTIC: LOST CHANGED	1	Enabled		New Value:	ļi —	
1	4	Bit1	STATISTIC: SYNC CHANGED	0	Disabled		Apply	value	
	4	Bit2	STATISTIC: REPEATS TOTAL CHAN	1	Enabled				-
	4	Bit3	STATISTIC: REPEATS MAX. CHANGE	1	Enabled		Reset To	Default	
	4	Bit4	STATISTIC: ILLEGALS CHANGED	1	Enabled				-
	4	Bit5	Statistic: Int. Diag changed	0	Disabled		Allowed Values:		
	4	Bit6	Statistic: Ext. Diag changed	0	Disabled		Value Meaning	-	
	4	Bit7	Statistic: Diag in DX changed	0	Disabled		0 Disabled	_	_
	5	BitO	ExtDiag. on LiveList change	0	Disabled		1 Enabled	j	
	5	Bit1	ExtDiag. on Baudrate error	0	Disabled				
	5	Bit2	ExtDiag. on Power error	0	Disabled				
	5	Bit3	ExtDiag. on Redundancy error	0	Disabled	Ŧ			
	•				•				
	Raw para	ameter info i	n Hex						
	00 00	00 00 7F	3 04 05 06 07 08 09 0A 0B 00 7 1D 00 00 3E 00 0A 05 01 00						
	10 00	00 00 00	0 00 00 00 00						
			Ok		Cancel				

Fig. 23 – You can choose which statistics trigger a diagnostic message

The following Statistics can trigger a diagnostic message of the Diagnostic Device:

- Lost changed
- Sync changed
- Repeats (total) changed
- Repeats (max) changed
- Illegals changed
- Internal Diagnostics changed
- External Diagnostics changed
- Diagnostics in Data Exchange changed

3.3.3 Extended Diagnostics on Events change

For more critical applications you can choose to enable the 'Extended Diagnostics' option for each of the previously mentioned events. In the case of such an event, the Diagnostics Device will send out a diagnostics message with the 'Extended Diagnostic' bit on. In a Busmonitor tool such as ProfiTrace the extended diagnostics bit will appear as a red blinking square.

All Events described in paragraph 3.3.1 can trigger the Extended Diagnostic bit of the Diagnostic Device. By default, the Extended Diagnostic option is disabled. Each item can be enabled individually.

40	41
ProfiHub-B5+ Diagnostics	51
60	61

	GSD C	Configuratio	on dialog (c) 2003-2012 PROCENTE	C V1.3.6						×
	Module S	election U	Iser Parameters Module Parameters	Standard	keywords					
	User Def	inable Para	meters							
	Offset	Datatype	Reference Name	Value	Meaning		Min. Valu	е	0	
	4	Bit5	Statistic: Int. Diag changed	0	Disabled		Max. Valu	ie	1	
	4	Bit6	Statistic: Ext. Diag changed	0	Disabled		Default V.	alue:	0	
	4	Bit7	Statistic: Diag in DX changed	0	Disabled		New Valu		0	
T	5	Bit0	ExtDiag. on LiveList change	0	Disabled		New Valu	e:	lo	
	5	Bit1	ExtDiag. on Baudrate error	0	Disabled			App	y value	
	5	Bit2	ExtDiag. on Power error	0	Disabled				,	
	5	Bit3	ExtDiag. on Redundancy error	0	Disabled			Reset	To Default	
	5	Bit4	ExtDiag. on Termination change	0	Disabled					
	5	Bit5	ExtDiag. on Channel change	0	Disabled		Allowed V	4		_
	6	Bit0	ExtDiagStat: Lost changed	0	Disabled		Value	Mean	-	
	6	Bit1	ExtDiagStat: Sync changed	0	Disabled		0	Disab		
	6	Bit2	ExtDiagStat: Reps. total changed	0	Disabled		1	Enab	ed	
	6	Bit3	ExtDiagStat: Reps. max. changed	0	Disabled					
	6	Bit4	ExtDiagStat: Illegals changed	0	Disabled					
	6	Bit5	ExtDiagStat: Int. Diag changed	0	Disabled	-				
	•				•					
	Raw par	ameter info i	in Hex							
	00	01 02 01	3 04 05 06 07 08 09 0A 0B (
		00 00 78								
			0 00 00 00 00 00 00 00 00 00 00 00 00 0	00 00 00	00					
							,			
			Ok	1	Cancel					
				-						

3.3.4 Extended Diagnostics on Statistics change

The Extended Diagnostic option can also be enabled for each individual available statistic. This works the same way as the Events described in paragraph 3.3.1.

ſ	GSD C	Configuratio	on dialog (c) 2003-2012 PROCENTE	C V1.3.6				
	Module S	election U	ser Parameters Module Parameters	Standard k	keywords			
	User Del	inable Para	meters					
	Offset	Datatype	Reference Name	Value	Meaning		Min. Value 0	
	5	Bit3	ExtDiag. on Redundancy error	0	Disabled		Max. Value 1	
	5	Bit4	ExtDiag. on Termination change	0	Disabled		Default Value: 0	
	5	Bit5	ExtDiag. on Channel change	0	Disabled		New Value: 0	
K	6	Bit0	ExtDiagStat: Lost changed	0	Disabled		New Value: 10	
	6	Bit1	ExtDiagStat: Sync changed	0	Disabled		Apply value	
	6	Bit2	ExtDiagStat: Reps. total changed	0	Disabled			
	6	Bit3	ExtDiagStat: Reps. max. changed	0	Disabled		Reset To Default	
	6	Bit4	ExtDiagStat: Illegals changed	0	Disabled	_	Allowed Values:	
	6	Bit5	ExtDiagStat: Int. Diag changed	0	Disabled			
	6	Bit6	ExtDiagStat: Ext. Diag changed	0	Disabled		Value Meaning	
Y	6	Bit7	ExtDiagStat: Diag in DX changed	0	Disabled		0 Disabled	
	7	BitO	Relay on LiveList Change	0	Disabled		1 Enabled	
	7	Bit1	Relay on Baudrate change	1	Enabled			
	7	Bit2	Relay on Power error	1	Enabled			
	7	Bit3	Relay on Redundancy error	1	Enabled	Ŧ		
	٠ 📄				۱. ۲			
	Raw par	ameter info i	n Hex					
	00 00	00 00 7F	104 05 06 07 08 09 0A 08 03 04 05 01 0 03 00<					
			Ok		Cancel			,

3.3.5 Alarm Relay on Events change

The Alarm Relay on the ProfiHub can be switched on each Event described in paragraph 3.3.1. When such an Event occurs, the Relay will be switched immediately without delay. The only Event that can delay the switching of the Alarm Relay is the Lost event.

	🔄 GSD C	Configurati	on dialog (c) 2003-2012 PROCENTI	C V1.3.6				
	Module S	election U	ser Parameters Module Parameters	Standard	keywords			
	User Del	finable Para	meters					
	Offset	Datatype	Reference Name	Value	Meaning		Min. Value 0	
	6	Bit5	ExtDiagStat: Int. Diag changed	0	Disabled	_	Max Value 1	
	6	Bit6	ExtDiagStat: Ext. Diag changed	0	Disabled		Default Value: 0	
	6	Bit7	ExtDiagStat: Diag in DX changed	0	Disabled			
ľ	7	Bit0	Relay on LiveList Change	0	Disabled		New Value: 0	
	7	Bit1	Relay on Baudrate change	1	Enabled		Apply value	
	7	Bit2	Relay on Power error	1	Enabled			
	7	Bit3	Relay on Redundancy error	1	Enabled		Reset To Default	
	7	Bit4	Relay on Termination change	1	Enabled			
U	7	Bit5	Relay on Channel lost	1	Enabled		Allowed Values:	
Γ	8	BitU	RelayUnStat: Lost changed	U	Disabled		Value Meaning	
	8	Bit1	RelayOnStat: Sync changed	0	Disabled		0 Disabled	
	8	Bit2	RelayOnStat: Reps. total changed	0	Disabled		1 Enabled	
	8	Bit3	RelayOnStat: Reps. max. changed	0	Disabled			
	8	Bit4	RelayOnStat: Illegals changed	0	Disabled			
	8	Bit5	RelayOnStat: Int. Diag changed	0	Disabled	-		
	•					F.		
	Raw par	ameter info i	in Hex					
		01 02 0	3 04 05 06 07 08 09 0A 0B	יים מיו מיו	FIDE			
			- 1D 00 00 <u>3E</u> 00 0A 05 01					
			0 00 00 00 00					
	1							
			Ok	1	Cancel			
			UK		Lancei			

3.3.6 Alarm relay on Statistics change

The Alarm Relay on the ProfiHub can be switched (closed) on each change in Statistics, described in paragraph 3.3.2. When such an (enabled) Statistic change occurs, the Relay will be switched immediately without delay. The only Statistic that can delay the closing of the Alarm Relay is the Lost event.

		-	on dialog (c) 2003-2012 PROCENTE Iser Parameters Module Parameters		(eywords					•
	User Def	inable Para	meters							
	Offset	Datatype	Reference Name	Value	Meaning	^	Min. Valu	e	0	
	7	Bit2	Relay on Power error	1	Enabled		Max. Valu	ie	1	
	7	Bit3	Relay on Redundancy error	1	Enabled		Default V	alue:	0	
	7	Bit4	Relay on Termination change	1	Enabled		New Valu		0	
	7	Bit5	Relay on Channel lost	1	Enabled		New valu	ie.	lo	
T	8	BitO	RelayOnStat: Lost changed	0	Disabled			Apply	value	
	8	Bit1	RelayOnStat: Sync changed	0	Disabled					
	8	Bit2	RelayOnStat: Reps. total changed	0	Disabled			Reset To	Default	
	8	Bit3	RelayOnStat: Reps. max. changed	0	Disabled					
	8	Bit4	RelayOnStat: Illegals changed	0	Disabled		Allowed V			
	8	Bit5	RelayOnStat: Int. Diag changed	0	Disabled		Value	Meanin	<u> </u>	
	8	Bit6	RelayOnStat: Ext. Diag changed	0	Disabled		0	Disable		
	8	Bit7	RelayOnStat: Diag in DX changed	0	Disabled		1	Enabled	1	_
	9	Uint8	Diag change timeout (x 100msec)	10						
	10	Uint8	Device lost timeout (x 1sec)	5						
	11	Bit0	Data format of 16/32 bits values	1	Motorola, high-low-byte	-				
	•				Þ					
	Raw par	ameter info i	in Hex							
	00 00	00 00 78	3 04 05 06 07 08 09 0A 08 0 5 1D 00 00 3E 00 0A 05 01 0 5 00 00 00 00							
			Ok		Cancel					

3.3.7 Changing the Diagnostics duration/timeout

You can change the duration of the Extended Diagnostics warning in steps of 100 milliseconds. The default value is 10, so 1 second. The maximum value is 255.

Diffset	Datatype	Reference Name	Value	Meaning		Min. Value	0	
7	Bit2	Relay on Power error	1	Enabled	_	Max. Value	255	
7	Bit3	Relay on Redundancy error	1	Enabled		Default Value:	10	
7	Bit4	Relay on Termination change	1	Enabled				
7	Bit5	Relay on Channel lost	1	Enabled		New Value:	10	
3	BitO	RelayOnStat: Lost changed	0	Disabled		Án	oly value	
3	Bit1	RelayOnStat: Sync changed	0	Disabled			ny raiwo	
3	Bit2	RelayOnStat: Reps. total changed	0	Disabled		Reset	To Default	
3	Bit3	RelayOnStat: Reps. max. changed	0	Disabled				
3	Bit4	RelayOnStat: Illegals changed	0	Disabled		Allowed Values:		
3	Bit5	RelayOnStat: Int. Diag changed	0	Disabled		Value Mea	ning	
3	Bit6	RelayOnStat: Ext. Diag changed	0	Disabled				
2	B¥7	RelayOnStat: Diag in DX changed	0	Disabled				
3	Uint8	Diag change timeout (x 100msec)	10					
10	Uint8	Device lost timeout (x 1sec)	5					
11	Bit0	Data format of 16/32 bits values	1	Motorola, high-low-byte	-			
٠ 🗌					F.			
law par	ameter info i	in Hex						
00		3 04 05 06 07 08 09 0A 0B F 1D 00 00 3E 00 0A 05 01	0C 0D 0E					
		- 10 00 00 3£ 00 04 05 01	00 00 00	J UU				
10 00	00 00 00	5 00 00 00 00						

3.3.8 Changing the Device Lost timeout

The Diagnostics Device waits for a certain time before it considers a slave to be lost. This works in a similar way as the ProfiTrace Live List, where the background turns yellow when a slave stops communicating. This timeout can be changed in steps of 1 second. Default value is 5, and maximum value is 255.

	2	on dialog (c) 2003-2012 PROCENT		termined 1					
	inable Para		Stanuaru	Keywords					
Offset	Datatype	Reference Name	Value	Meaning		Min. Value	0		
7	Bit2	Relay on Power error	1	Enabled	-	Max. Value	255		
7	Bit3	Relay on Redundancy error	1	Enabled		Default Value:	5		
7	Bit4	Relay on Termination change	1	Enabled	-		-		
7	Bit5	Relay on Channel lost	1	Enabled		New Value:	5		
8	BitO	RelayOnStat: Lost changed	0	Disabled		Ann	ly value	1	
8	Bit1	RelayOnStat: Sync changed	0	Disabled		Abt	ny value		
8	Bit2	RelayOnStat: Reps. total changed	0	Disabled		Beset	To Default	1	
8	Bit3	RelayOnStat: Reps. max. changed	0	Disabled					
8	Bit4	RelayOnStat: Illegals changed	0	Disabled		Allowed Values:			
8	Bit5	RelayOnStat: Int. Diag changed	0	Disabled		Value Mear	ning		
8	Bit6	RelayOnStat: Ext. Diag changed	0	Disabled					
8	Bit7	RelayOnStat: Diag in DX changed	0	Disabled					_
9	Llint8	Diag change timeout (x 100msec)	10						
10	Uint8	Device lost timeout (x 1sec)	5						
11	BitO	Data format of 16/32 bits values	1	iviotoroia, high-low-byte	-				
•				•					
Raw par	ameter info i	in Hex							
00		3 04 05 06 07 08 09 0A 0B							
	00 00 71		00 00 0	00 0					
10 00	00 00 00	00 00 00 00 00 00							
						1			
		Ok	1	Cancel					

3.3.9 Changing the data format

The data format can be changed if needed. Default is Motorola, high-low-byte format. You can change it to Intel, low-high-byte format.

Offset	Datatype	Reference Name	Value	Meaning		Min. Valu	e	0
7	Bit2	Relay on Power error	1	Enabled		Max, Valu	Je	1
7	Bit3	Relay on Redundancy error	1	Enabled		Default V	alue:	1
7	Bit4	Relay on Termination change	1	Enabled				
7	Bit5	Relay on Channel lost	1	Enabled		New Valu	ie:	1
3	Bit0	RelayOnStat: Lost changed	0	Disabled			Ann	ly value
3	Bit1	RelayOnStat: Sync changed	0	Disabled				,
3	Bit2	RelayOnStat: Reps. total changed	0	Disabled			Reset	To Default
3	Bit3	RelayOnStat: Reps. max. changed	0	Disabled				
3	Bit4	RelayOnStat: Illegals changed	0	Disabled		Allowed \	4	
3	Bit5	RelayOnStat: Int. Diag changed	0	Disabled		Value	Mean	2
3	Bit6	RelayOnStat: Ext. Diag changed	0	Disabled		0		low-high-byte
3	Bit7	RelayOnStat: Diag in DX changed	0	Disabled		1	Motor	ola, high-low-byte
Э	Uint8	Diag change timeout (x 100msec)	10					
	Llint8	Device lost timeout (x 1sec)	5					
ш		Data format of 16/32 bits values		Motorola, high-low-byte	-			
11								
1	Bit0				P			
1 ∢	1	·			•			
1 ∢	Bit0 rameter info	·			•			
I1 ∢ 📄 aw pa	rameter info	·	0C 0D 01	EOF	F			
1	rameter info	in Hex 3 04 05 06 07 08 09 04 08	<u>0C 0D 01</u> 00 00 01		•			
1 aw pa 00 00 00	rameter info 01 02 0 00 00 7	in Hex 3 04 05 06 07 08 09 04 08			•			
10 11 ∢ 🔲	1	·			•			

3.4 ProfiTrace plugin for the Diagnostic Device

On the download section of www.procentec.com you can download a useful plugin for the Diagnostic Device. It interprets all messages to and from the Diagnostic Device and displays the data in the Info Panel of ProfiTrace.

3.4.1 Installing the Plugin

Once you have downloaded the file and extracted it to your hard drive, start ProfiTrace and choose 'Settings – Plugins' to bring up the Plugin window.

Click 'Install Plugin' and locate it on your harddrive. Next, click 'Enabled' so that ProfiTrace starts the plugin on startup.

g_diagnostic_Device Yes	abled Vendor s PROCENTEC			ription nostic device Plugin
Nugin info & settings I Enabled Capabilities: Info Panel Message Scan Meg. Mem. record. General msg. info	General setup Setup Setup Setup Setup	↓ ↓ Enabled ↓ ↓ Enabled ↓ ↓ Enabled ↓ ↓ Enabled	Description General in Version Build : Vendor Division : Author : Development tool : Plugin API version :	nfo Supported Ident Nrs V1.0 0 PROCENTEC RD Vera Bolfand C++ Builder V6.0 V1.1

3.4.2 Using the Plugin

When the Plugin is correctly started and you have a ProfiHub with Diagnostics Device running, click 'Start Message Recording' in ProfiTrace, and view the screen with messages (see Fig. 24). If you click on a data exchange message to or from a Diagnostics Device, you will see all the interpreted data bytes in the Info Panel. This is very useful for Troubleshooting activities.

A good example is the Statistics. These statistics are available per individual channel or station address (see paragraph 3.3.2), so it is easy to see the source of the problem.

ofiTrace 🌑 Overview ScopeWare Bargraph Topol	ogy Network Manager P	ofiCaptain							
Load Data Save Data File viewer Setup record	I trigger Start message r	cording Sto	op message recordir	ng Set re	ecord filter Set vi	ew filter			
Init ProfiCore Ultra Close ProfiCore Ultra Auto-detec	t baudrate Set baudrate	typs	▼ Wizard						
ystem activity: Live list : 🙍 Message recording : 🔀	Record to file : 🗙								
fo Panel	🎔 Live list 🖾 Messa	nes 🔽 Mess	ages (with view filte	r applied) 🛛	Station statistics	view 🛛 🔎 Data inspectio	n		
ramestructure: SD2 message	Setup Search Search	A Searc	h Down 🛛 🗖 Baw	frames	Stick To Bottom				
ource address: 20									
<pre>Kodel_Name: ProfiHub-B2+ Diagnostics</pre>	FrameNr Timestamp	At cid		Addr	Service	Msg type	Reg/Res SAPS	DataLen	
estination address:	0 11-Jul-2		SD2	1<-20	DL	Data Exchange	Res	64	00 01 (
ametype: Response message	1 11-Jul-2		SD4	1->1	Token pass	Pass token			
ROFIBUS DP-VO Message:	2 11-Jul-2		SD2	1->20	SRD_HIGH	Data Exchange	Reg	4	FF 00
COFIDUS DF-VO Message: Data Exchange (Con/Res)	3 11-Jul-2		SD2	1<-20	DL	Data Exchange	Res	64	00 01
Data Exchange (Con/Res)	4 11-Jul-2		SD4	1->1	Token pass	Pass token			
agnostic device plugin info:	5 11-Jul-2		SD2	1->20	SRD_HIGH	Data Exchange	Reg	4	FF 00
agnostic device plugin info: wice type: B2+	6 11-Jul-2		SD2	1<-20	DL	Data Exchang	Res	64	00 01
	7 11-Jul-2		SD1	1->22	FDL Status		Reg		
ersion: 0x01 eta format: Motorola, high-low-byte	8 11-Jul-2		SD4	1->1	Token pass	Pass token			
ita format: Motorola, high-low-byte	9 11-Jul-2		SD2	1->20	SRD_HIGH	Data Exchange	≥q	4	FF 00
	10 11-Jul-2		SD2	1<-20	DL	Data Exchange	Res	64	00 01
atus cable redundancy: Redundancy not used	11 11-Jul-2		SD4	1->1	Token pass	Pass token			
	12 11-Jul-2		SD2	1->20	SRD_HIGH	Data Exchange	Reg	4	FF 00
elay status: Relay is on	13 11-Jul-2		SD2	1<-20	DL	Data Exchange	Res	64	00 01
	14 11-Jul-2		SD4	1->1	Token pass	Pass token			
ower status:	15 11-Jul-2		SD2	1->20	SRD HIGH	Data Exchange	Reg	4	FF 00
ower 1 active	16 11-Jul-2		SD2	1<-20	DL	Data Exchange	Res	64	00 01
ending alarm: Power 2 not active	17 11-Jul-2		SD4	1->1	Token pass	Pass token			
	18 11-Jul-2		SD2	1->20	SRD HIGH	Data Exchange	Reg	4	FF 00
ermination:	19 11-Jul-2		SD2	1<-20	DL	Data Exchange	Res	64	00 01
ain channel termination	20 11-Jul-2		SD4	1->1	Token pass	Pass token			
nannel 1 termination	21 11-Jul-2		SD2	1->20	SRD HIGH	Data Exchange	Reg	4	FF 00
	22 11-Jul-2		SD2	1<-20	DL	Data Exchange	Res	64	00 01
ive list information:	23 11-Jul-2		SD4	1->1	Token pass	Pass token			
irrent Selection:	24 11-Jul-2		SD2	1->20	SRD HIGH	Data Exchange	Reg	4	FF 00
omplete device	25 11-Jul-2		SD2	1<-20	DL	Data Exchange	Res	64	00 01
asters: 1;	26 11-Jul-2		SD4	1->1	Token pass	Pass token			
laves: 20;50;	27 11-Jul-2		SD2	1->20	SRD HIGH	Data Exchange	Reg	4	FF 00
	28 11-Jul-2		SD2	1<-20	DL	Data Exchange	Res	64	00 01
atistics data:	29 11-Jul-2		SD4	1->1	Token pass	Pass token			
rrent Selection: Complete device	30 11-Jul-2		SD2	1->20	SRD HIGH	Data Exchange	Reg	4	FF 00
ost count: 1	31 11-Jul-2		SD2	1<-20	DL	Data Exchange	Res	64	00 01
rnc count: 25	32 11-Jul-2		SD4	1->1	Token pass	Pass token			
otal repeat count: 2	33 11-Jul-2		SD2	1->20	SRD HIGH	Data Exchange	Reg	4	FF 00
ax repeat count: 1	11-001-2			1 - 10	Ser Harri		-verg		
legal count: 217									

Fig. 24 - Info Panel with ProfiHub Diagnostics information

4 Technical Data ProfiHub B5+R

Te	echnical Data ProfiHub B5+R
Dimensions and weight	
Dimensions L x W x H (mm)	167 x 113 x 35 mm (excluding DIN-rail and plug-able
	connectors)
Weight	650 g (excluding plug-able connectors, cable brackets and packing material).
Mounting DIN-rail type	35mm × 7,5mm (EN 50022, BS 5584, DIN 46277-3)
Ambient conditions	-25 to +70° Celsius
Operating temperature	-13 to +158° Fahrenheit
	IP 20 (IEC/EN 60529, DIN 40050)
Isolation class Protocol and timing specifications	
Supported Protocols	DP-V0, DP- V1, DP-V2, FDL, MPI, FMS, PROFIsafe, PROFIdrive
	and any other FDL based protocol.
Transmission speed	9.6 kbps to 12 Mbps (including 45.45 kbps)
Transmission speed detection	Auto detect
Transmission speed detection time	< 10 s detection and 50 s baudrate switchover time.
Rotary Switch settings	Rotary Auto Robust Redundancy Diagnostic
	switch detect repeating slave
	0 •
	3 • • • •
	6-F •
	For older ProfiHubs refer to paragraph 2.10.1
Data dalay timo unit	At baudrate Normal mode Robust/Redundant mode
Data delay time unit	9.6 - 500 kbps 3.0 Tbit 14 Tbit
	1.5 Mbps 4.0 Tbit 15 Tbit
	3 Mbps 4.5 Tbit 15 Tbit
	6 Mbps 5.0 Tbit 16 Tbit 12 Mbps 7.0 Tbit 18 Tbit
Jitter per message frame	0.0625 Tbit at 9.6 Kbps - 3 Mbps
	0.125 Tbit at 6 Mbps
	0.25 Tbit at 12 Mbps
Deviation	2 bit times (over the complete message) for received messages is allowed and is corrected to nominal speed when
	transmitted.

PROFIBUS Diagnostics Device specifications			
	DP-V0		
Supported protocol Ident Number	6970		
		1	
GSD filename	PROC6970.gsd	1	
Bus address	0-126 (softwa	re address only, set by sc	oftware, default 126)
Transmission speed	9.6 kbps to 12	Mbps (including 45.45 k	bps)
Transmission speed detection	Auto Detect		
Maximum transferrable data	85 bytes input	and 5 bytes output	
PROFIBUS cable specifications			
Cable lengths	1200 m at 9.6	kbps to 93.75 kbps	
	1000 m at 187	'.5 kbps	
	400 m at 500	kbps	
	200 m at 1.5 M	/lbps	
	100 m at 3 Mi	ops to 12 Mbps	
Cable thickness	10 mm (when	the ground rail is used)	
Wire diameter	< 2.5 mm ²	,	
Wire type	Stranded or S	olid core	
Number of devices	Maximum 31	per Channel (including Pr	ofiHubs, OLMs,
	Laptops/PCs,		, ,
Tennelinetien	Integrated and	d cwitchable	
Termination		rding to IEC 61158 (390/	220/200 Ohms
	- All Channels		220/390 011115)
	- Main-Channels		
Redundancy	Yes (Channel	l and 5)	
Cascading depth	No limits (only	limited by busparamete	rs of the master)
	With standard	busparameters:	
	At baudrate	Normal mode[units]	Robust mode[units]
	9.6 kbps	6	1
	19.2 kbps	6	1
	45.45 kbps	39	8
	93.75 kbps	6	1
	187.5 kbps	6	1
	500 kbps	16	3
	1.5 Mbps	20	5
	3 Mbps	17	5
	6 Mbps	13	4
	12 Mbps	13	5
	12 10 0 0 5	15	5
	Formula to ca Tslot :	culate number of cascad	ing units with adjusted
		ding units = (Tslot - maxT	sdr) / (2 ×
	Data_delay_ti		
		time_unit: Normal or Rol	bust mode see table
	/ _		
·			

Power supply specifications	
Power supply operating voltage	12 to 24 VDC
Power supply absolute max. rated voltage	9 to 31 VDC
Redundant power supply	Yes
Redundant power supply	
Current consumption	275 mA at 24 V power supply (all Channels fully loaded)
Power dissipation	Max. 2.8 W
Reverse polarity protection	Yes
Wire diameter	< 2.5 mm ²
Alarm contact	
Voltage	Max. 24 VDC
Current	Max. 0.5 A
Connector lay-out	
Power supply POW 1 and POW 2	Plug-able screw connector, pitch 5,08 mm
	Pin + : 12 to 24 VDC
	Pin - : 0 V
	Screw: Shield
	Serew. Shield
Alarm	Plug-able screw connector, pitch 5,08 mm
	Pin 1: relay contact (potential-free)
	Pin 2: relay contact (potential-free)
PROFIBUS screw terminals Main Channel	Plug-able screw terminal, pitch 3,81 mm
and Channel 1 to 5	Pin A: PROFIBUS A (green wire)
	Pin B: PROFIBUS B (red wire)
	Pin I : Indirect shield
	D Sub connector, 0 contacts (DBOCIDUS specification)
PROFIBUS DB9 Main Channel and Channel 1 to 5.	D Sub connector, 9 contacts (PROFIBUS specification) Pin 1: N.C.
1 (0 5.	Pin 2: N.C.
	Pin 3: PROFIBUS - B
	Pin 4: PROFIBUS - RTS
	Pin 5: GND
	Pin 6: VPP
	Pin 7: N.C.
	Pin 7: N.C. Pin 8: PROFIBUS - A
	Pin 9: N.C.
	Housing: Shield
	Tousing, Shielu
	Shield is connected internally to the DIN-rail
	Pin I is connected internally with 10nF/1MOhm to shield.
	, , ,

Standards and approvals CE	EMC Directive 2014/30/EU, class B Digital Device RoHs Directive 2011/65/EU
FCC	47 CFR 15, Unintentional Radiator, class B Digital Device.
UL	Report reference: E365044-A1-UL
	Standards for safety: UL 60950-1, Information Technology Equipment - Safety - Part 1 General Requirements
	CAN/CSA C22.2 No. 60950-1-07, Information Technology Equipment - Safety - Part 1: General Requirements
DNV	Certificate number: A-13659
	Location classes:
	 Temperature: D Humidity: B Vibration: A EMC: B Enclosure: IP20 (IEC/EN 60529,DIN 40050)
MTBF	398723 hours according to IEC-62380 (RDF2000/UTE C 80-180)

5 Order codes

Component	Order code	Remarks
ProfiHub B5+R	17020R	ProfiHub B5+R with Diagnostics Device With Alarm contact With redundant power input With cable redundancy Note: since January 2019, all types have been merged into this single type. All types are drop-in replaceable.

6 Glossary

Address	Unique number of a device connected to the network. With PROFIBUS this can be 0 to 126. 127 is a broadcast address.
Analyzer	Software tool to observe the protocol traffic. Combi-Analyzers can also inspect the signal quality. Other term: Bus Monitor. Example: ProfiTrace.
Backbone	The primary bus cable. Most of the time only the control systems, ProfiHubs and fiber optic couplers are connected to this cable. The field devices are connected behind the ProfiHubs and fiber optic couplers.
Bit Time (Tbit)	The bit time Tbit is the time, which elapses during the transmission of one bit. It depends on the baudrate and is calculated as follows Tbit = 1 (bit) / baudrate (bps). Examples: 12 Mbps> Tbit = 83 ns 1.5 Mbps> Tbit = 667 ns
Busparameters	Settings that define the timing behaviour on the bus. They are defined in the master. Examples: Tslot, MaxTSDR.
C	Capacitance.
C DGND	Capacitance. Digital Ground.
DGND	Digital Ground.

DP-V2	 DP-V2 is the second stage of extension of PROFIBUS DP after DP-V1. DP-V2 devices shall comply with the following features: Data Exchange Broadcast (DxB) for slave to slave communication (publisher/subscriber principle). Isochronous Mode (time tick synchronized operating slaves, e.g. drives) Up- and/or download of Load Region Data (domains) Clock Control (synchronization within slaves) and Time Stamping Redundancy.
Electromagnetic Compatibility	See EMC.
EMC	The extent to which an electric or electronic device will tolerate electrical interference from other equipment (immunity), and will interfere with other equipment. Within the European Community as well as in other countries it is regulated by law that electric and electronic components and equipment comply with basic standards such as IEC 61000-6-2 or IEC 61326 or corresponding individual product standards.
Hub	A Hub refreshes a signal and passes the information on to all nodes which are connected to the Hub. Data frames which were received on one port are transferred to all the other ports (chicken foot topology).
MPI	Multiple Protocol Interface. Protocol defined by Siemens which uses the layer 1 and 2 of PROFIBUS (FDL).
PCB	Printed Circuit Board.
PROFIBUS DP	Acronym for "PROFIBUS for Decentralized Peripherals". Specification of an open fieldbus system with the following characteristics: - Polling master-slave-system (cyclic communications, MSO) - Flying masters with robin round token passing coordination (MM) - Connection based (MS1) and connectionless (MS2, MS3) acyclic communication between masters and slaves Options (e.g.): - Data exchange broadcast (DXB), i.e. slave to slaves communication - Isochronous mode of slaves - Clock synchronization - Redundancy PROFIBUS DP is standardized within IEC 61158 and IEC 61784, communication profile families 3/1 and 3/2 The term "PROFIBUS DP" also is a synonym for the RS485 based deployments within factory automation.
Repeater	Active physical layer device that receives and retransmits all signals over a different port to increase the distance and number of devices for which signals can be correctly transferred for a given medium.
Spur line	A cable attached to a bus segment with a T-connection . Spurs are not recommended with PROFIBUS DP. They are prohibited with 12 Mbps and PROFIsafe operations. German term is "Stichleitung".
Stub line	See Spur line.

Tbit	See Bit Time.
Termination	A (powered) resistor network at both ends of a segment to prevent reflections (with PROFIBUS DP the termination must be powered).
Topology	In a communications network, the pattern of interconnection between network nodes; e.g. bus, ring, star configuration.
PI	PROFIBUS International. The International PROFIBUS Organization based in Karlsruhe.
PNO	PROFIBUS Nutzer Organization. The German PROFIBUS Organization based in Karlsruhe.
Drop cable	See <i>Spur line</i> .
Reflection	Part of the original signal that is transmitted back along the cable. It corrupts the original signal.

8 Revision History

Version 1.0

- First release (B5+)

Version 1.5

- Added the UL and DNV certificates
- Updated the Distributors chapter

Version 2.0

- Added chapter 'Diagnostics Device'
- Textual changes in all chapters to adapt to B5+R

Version 2.1.0

- Textual changes

Version 3.0

- Updated the manual to the new corporate style

Version 3.0.4

- Updated chapter 'Technical Data'

Version 4.0.0

- Changed manual to adapt to Diagnostics feature for ProfiHub family and ComBricks.

10 Certificates





erti

QualityMasters hereby declares that

Procentec B.V. Wateringen

has a management system that meets the requirements of the standard

NEN-EN-ISO 9001:2015

for the scope

Providing training courses, technical support, product development and the exploitation of the test laboratory.

Date of original approval	10-02-2003
Date of issue	27-01-2017
Valid until	10-02-2019
Certificate number	NL 6594-uk-a

On behalf of Stichting QualityMasters,

N.B. The failure to meet the conditions as set forth in the certification agreement, or non-compliance with the given standard and/or guidelines, may lead to the suspension or cancellation of the certificate. This certificate remains the property of Stichting QualityMasters, Nieuwland Parc 157, 3351 LJ Papendrecht.





Certificate for a PI Competence Center

PI confirms that

PROCENTEC **Elmer Vis** Klopperman 16 2292 JD Wateringen **NETHERLANDS**

is a fully accredited PI Competence Center for **PROFIBUS** basic **PROFIBUS** Process Automation PROFIsafe.

This certificate is granted according to the Quality of Services Agreement for PI Competence Centers and is valid for 2 years, until December 31, 2019.

Jefer Wentel

(Official in Charge)

Chairmen of PI

(Karsten Schneider, Chairman)

(Michael Bowne, Deputy Chairman)



Certificate

PROFIBUS Nutzerorganisation e.V. grants to

PROCENTEC Klopperman 16, 2292 JD Wateringen, The Netherlands

the Certificate No: Z02188 for the PROFIBUS device:

Model Name:	ProfiHub-B5+RD Diagnostics
Revision:	1.0; SW/FW: 2.0; HW: 1.3
GSD:	PROC6970.GSD File Version: 2.0

This certificate confirms that the product has successfully passed the certification tests with the following scope:

DP-V0	MS0, Sync, Freeze, Auto_Baud, Set_Slave_Add
Physical Layer	RS485

Test Report Number: Authorized Test Laboratory: PCN208-DPS-01 PROCENTEC, Wateringen, The Netherlands

The tests were executed in accordance with the following documents: "Test Specifications for PROFIBUS DP Slaves, Version 3.09 from September 2008". This certificate is granted according to the document:

"Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by January 02, 2022 the certificate is valid for life.

Karlsruhe, January 29, 2019

(Official in Charge)



Board of PROFIBUS Nutzerorganisation e. V.

(Karsten Schneider)

- 4

(Dr. Jörg Hähniche)



About PROCENTEC

PROCENTEC is a specialist in PROFIBUS and PROFINET technology and develops products to optimize the production processes of end users. Our innovative solutions ensure that our customers successfully operate in the world of industrial automation and enjoy maximum results from their process.

PROCENTEC globally supplies all the components required to install a measurable and steerable network. We develop and produce all products in the Netherlands and they are exported through our worldwide distribution network. At PROCENTEC, we have a professional team of qualified support engineers who provide technical support on-site and online. Our professionals have more than 20 years of experience with PROFIBUS and PROFINET technology. They provide the necessary support to end users during implementation procedures, certification processes, audits and malfunctions. PROCENTEC also is the international accredited Competence and Training center for PROFIBUS and PROFINET. We provide training courses that help employees using those techniques optimally for their business objectives.

Products

- ProfiTrace
- ComBricks
- ProfiHub
- PROFINET tools
- Cables and connectors

Training courses

- PROFIBUS training courses
- PROFINET training courses
- Product training courses

Services

- Competence center
- Support & Consultancy
- Network certification & Audits
- Testlab & Democenter

